

REVERSE OSMOSIS

Replacement cartridges

Reverse osmosis system shipped with Maxi One unit consists set of 4 filters:

- 1 - **AIRPRO-1M-TW** – sediment removal
- 2 - **AISTRO-2-TW** – iron removal
- 3 – **FCCBL-S-TW** – organic – heavy metals
- 4 – **TLCHF-TW** – ultrafiltration – antibacterial.

Cartridges should be replaced minimum once a year. If quality of delivered water is poor (eg. high concentration of iron or other particles), then cartridges should be replaced more often (every 3-6 months).